



INDEPENDENT  
SCHOOL DISTRICT

1515 Cherrybrook  
Pasadena, TX 77502  
Tel 713.740.0198  
Fax 713.740.4033

December 3, 2013

Addendum 1:

**14-024: CABLING**

- 1) There is a lot of discussion relative to “LAN” cabling and specs for LAN cabling, however there is no LAN cabling identified on the pricing sheets. We assume this RFP is for backbone cabling and there is no “LAN” cabling included in the groups or pricing?
  - a. **Correct.**
- 2) There is reference regarding various warrantee requirements including 12 months, 25 year and lifetime. How should we respond?
  - a. **The vendor should clearly document the installers’ certifications, warrantee period covered for installation and product and who will be providing the warrantee, the installer or the manufacture and any conditions to the warrantee. This will be part of the selection criteria.**
- 3) Would it be possible to get the RFP response docs in an editable form?
  - a. **Yes. Download at <http://www.eps4.com/14-024-Forms.docx> .**
- 4) Should we assume that we can use the existing pathway support or do we want to install all new pathway supports?
  - a. **Use existing where possible. Replace, repair and/or add where necessary to ensure BICSI and manufacture standards are met.**
- 5) Do we need to demo the existing fiber optic cable after new cable is complete?
  - a. **Yes.**
- 6) Are there IDF’s that requires pulls located in portables? If there are, is Indoor/Outdoor plenum fiber optic cable required for these pulls?
  - a. **Yes.**

- 7) If there are portables, please identify the quantity of same on a per school basis within the tables provided for each group
  - a. Refer to section 4.7. Runs greater than 300 meters are outdoor/portable runs.
- 8) Are there any outdoor pulls, i.e. underground in new conduit or in old conduit or on canopy in conduit provided? If yes, how many and what are the specifications for the cable. (I/O Plenum?)
  - a. Refer to section 4.7. Runs greater than 300 meters are outdoor/portable runs. Yes, the specifications are indoor/outdoor plenum 50 micron multimode such as P-012-LN-5M-F12BK/25D
- 9) How do we need to price P&P bonds? The price sheet provides pricing inclusion for “other Costs” on an aggregate basis, however, when PISD has issued Po’s in the past it is not for the entire project, but on a per school basis.
  - a. Bond costs should be included in other costs by campus. Final bond (if any) requirements will be determined during contract negotiations with the vendor of choice.

**NOTE:**

Please acknowledge receipt of this addendum by signing and dating this page and include a copy with your proposals.

Signature \_\_\_\_\_ Date: \_\_\_\_\_